

PUBLIC WORKS DEPARTMENT

JANUARY 2014

Public Works Department continued work on Main Street and the cemetery getting a big jump on these areas and trying to get ready for the Apache Leap Mining Festival. I, Anthony Huerta, am getting certified for weed control spraying by the end of the month. The Department has a good handle on the vehicles. There's still a need for Police Department vehicles to get them on line. We are waiting on a couple of different avenues to finish getting the parts and tires and look forward to having at least four vehicles going for at least two years, other than scheduled maintenance. We are working on having two other vehicles on backup be ready to go in the future.

We have had nine funerals and been working on the cemetery clean up while digging for these services. Public Works has a compressor and 80 pound digging spade, which will also be on line after new hose connections and maintenance is done. This is a vital need in digging any graves by hand when the backhoe is unable to be used.

Margaret and I met with a committee from the LDS and have made plans on a big cleanup to the cemetery on March 21, 2014. We will have approximately 160 kids here to perform the cleanup. They will be furnishing all the tools, the weed killer and paint. We are hoping to not only having the cemetery cleaned up, but all the trash barrels being painted at the cemetery. They will also be documenting all the graves at the cemetery so people can look them up online eventually.

Public Works Department has cleaned up all of the downtown Main Street in preparation for Apache Leap Mining Festival in March, and have continued west on Main Street to get the entire street done.

Anthony Huerta
Publics Works Supervisor

Town of Superior

Sanitation Report

***February 18, 2014
for month of January
2014***

The facility is in compliance.

5,528,000 gallons were treated.

5,203,800 gallons were discharged to the wash

324,200 gallons of effluent delivery to the school

Issues/Projects:

Construction ongoing.

Compliance Sampling:

All sampling results were in compliance.

Blue Stake:

1 Blue stake request was completed.

Septage dumping:

46,500 gallons were taken in.

Effluent Quality Summary

Constituent	Permit Limit	Discharge Results	High Reading	Low Reading	Average Reading
Fecal Coliform	0 (4 of 7)	0	4	0	0.2
Fecal Coliform Max	23	0	4	0	0.2
E Coli (Weekly)		0	3	0	0.3
Flow Gallons per Day	500,000		199	169	183
Total Nitrogen (mg/l)	10.0	8.04 mg/l			
Turbidity Daily Ave (ntu)	2		1.1	0.4	0.6
Turbidity Daily Max (ntu)	5		3.01	0.2	1.2