

TOWN OF SUPERIOR
PUBLIC WORKS DEPARTMENT

APRIL REPORT 2014

This month scrap collection reached \$217.86. Further plans have been made regarding posting on the Town's billboard on continued efforts to collect scrap metal. Any and all metal will be collected to use proceeds to benefit Public Works shop needs.

This month the Church of Latter Day Saints has again cleaned at the cemetery; accumulating approximately 20 bags of weeds collected during the cleanup. Again, our thanks from the Public Works and the Town go out to them.

This month the Public Works Department has started to work on pot holes and continued with the street cleaning. The areas of Stone and Highway 177; and Highway 60 to Sunset Drive; the entire south east area of town has been cleaned. Any of the areas left will be cleaned by April 18, Friday. We have been working hard to accomplish this besides all of our normal daily tasks.


Also, the areas of both Highway 60 and the Caboose Park have been cleaned again in an effort to keep up with the needs and wishes of the public. My thanks goes to the crew and inmates for their efforts in the two areas.

I, Anthony Huerta, have put in a lot of effort and hours to again cleanup and maintain the Town's swimming pool to have it ready by our projected date of Memorial Day weekend.

Efforts have continued by Shop Mechanic Manny Ramirez to repair our bucket lift truck and equipment, to a point where our Public Works Department has almost all the entire inventory up and running with only monthly maintenance required in the future. We owe Manny Ramirez a big thank you. Maintenance needs could be batteries, tires, tune up equipment, and oxygen and acetylene tanks.

The new hire this month is Argel Quiroz, part time for Public Works. Argel will be a great help with the pot hole efforts, helping with the Senior Citizens, and special projects in town.

Respectfully submitted,


Anthony Huerta
Public Works Supervisor

***Town of Superior Sanitation Report April, 2014 for the
month of March***

The facility is in compliance.

5726,000 gallons were treated.
2,576,000 gallons were discharged to the wash
315,000 gallons of effluent delivery to the school

Issues/Projects:

Reviewed the Preliminary Engineering Report by NCS.

Compliance Sampling:

All samplings were in compliance.

Blue Stake:

5 Blue stake requests were completed.

Septage dumping:

57,700 gallons were taken in.

Effluent Quality Summary

| Constituent | Permit Limit | Discharge Results | High Reading | Low Reading | Average Reading |
|----------------------------|--------------|-------------------|--------------|-------------|-----------------|
| Fecal Coliform | 0 (4 of 7) | 0 | 0 | 0 | 0 |
| Fecal Coliform Max | 23 | 0 | 0 | 0 | 0 |
| E Coli (Weekly) | | 0 | 0 | 0 | 0 |
| Flow Gallons per Day | 500,000 | | 236 | 154 | 184 |
| Total Nitrogen (mg/l) | 10.0 | 4.53 mg/l | | | |
| Turbidity Daily Ave (ntu) | 2 | | 1.8 | 0.4 | 0.8 |
| Turbidity Daily Max (ntu) | 5 | | 3.0 | 0.1 | 0.1 |